



PROPOSED BASEMENT PLAN
Scale 1:100



- DUCT
- SUPPLY
- EXTRACT

HEALTH CLUB - 7 AIR CHANGES PER HOUR = 3115M3/HR - DUPLEXVENT FLEXI DV3600

WINE BAR
FEMALE WC - 10 AIR CHANGES PER HOUR = 1655M3/HR
MALE WC - 10 AIR CHANGES PER HOUR = 1655M3/HR
DUPLEXVENT FLEXI DV2600

A	21.07.16	PLANNING SUBMISSION
Rev:	Date:	Amendment:



The Studio, 8 The Carters, Thundersley,
Bentley, Essex, S87 3DJ
Tel: 01702 555411 / Fax: 01702 555411
E: info@stoneme.com W: www.stoneme.com

Client: MR M NORCROSS

Project: THE GRAND HOTEL
LEIGH-ON-SEA
ESSEX

Drawing: PROPOSED BASEMENT VENTILATION

Date: 16.11.2015 Scale: 1:100 @ A1

Project No.: Drawing No.: