



PROPOSED GROUND FLOOR PLAN
Scale 1:100



- DUCT
- SUPPLY
- EXTRACT

- FUNCTION ROOM
BRASSERIE - 10 AIR CHANGES PER HOUR = 1535M³/HR DUPLEXVENT FLEXI DV2600
- RESTAURANT - 10 AIR CHANGES PER HOUR = 1465M³/HR DUPLEXVENT FLEXI DV2600
- KITCHEN - 10M CANOPY, 2M/S AT FILTER FACE, 30 AIR CHANGES P/HR

A	21.07.16	PLANNING SUBMISSION
Rev:	Date:	Amendment:



The Studio, 8 The Caners, Thundersley,
Benfleet, Essex, S87 3DJ
Tel: 01702 555411 / Fax: 01702 555411
E: info@stoneme.com W: www.stoneme.com

Client: MR M NORCROSS

Project: THE GRAND HOTEL
LEIGH-ON-SEA
ESSEX

Drawing: PROPOSED GROUND FLOOR
VENTILATION

Date: 16.11.2015 Scale: 1:100 @ A1

Project No.: Drawing No.: