


ALL WORKING DIMENSIONS TO BE CHECKED ON SITE.
 FIGURED DIMENSIONS TO BE TAKEN IN PREFERENCE TO SCALED DIMENSIONS.
 ANY DISCREPANCIES BETWEEN DRAWINGS OF DIFFERING SCALES AND BETWEEN DRAWINGS AND SPECIFICATION WHERE APPROPRIATE TO BE NOTIFIED TO SUPERVISING OFFICER FOR DECISION.
 COPYRIGHT RESERVED.



SCALE BAR 1:500



NOTES:


Floodlighting Equipment
 4 x 10m Masts (M1-M4)
 Each carrying the following Floodlights :-
 M1-M4
2 x FL11 MAXI PL33T 2 BRICK BLC
Lamps = SITECO LED - 100,000 Lumen
Illuminance Levels
Initial
 (100hrs) E.Lave = 257Lux
Maintained
 (4000hrs) E.Lave = 231Lux
Uniformity
 Emin/Eave = 0.66
 Grid values in Lux (Initial).
 Grid Interval = 5m.
 Contour values in Lux (Initial).
 Contours: 5, 15, 25, 50 Lux.
Maintenance Factor = 0.90

Rev	Date	Notes
2	06/05/2022	Updated pitch
1	27/04/2022	Updated title, added lighting notes.
0	21/04/2022	Initial Issue.

Rev Date: Notes:
 REVISION HISTORY

**NEW 60X40 YARD FLOODLIT
 3G FTP
 at
 PRINCE AVENUE PRIMARY
 HORNBY AVENUE
 SOUTHEND-ON-SEA
 WESTCLIFF-ON-SEA, SS0 0LG
 SOUTH EAST ESSEX ACADEMY
 TRUST**

PROPOSED FLOODLIGHTING



PCH
 ASSOCIATES
 LTD

01638 667676
www.pchassociates.co.uk
info@pchassociates.co.uk

06 May 2022	PR
1:500 @ A1	DT
201-15_PL-06.R2	

